



Email ID :- ee_cd_ferozabad@yahoo.in

CUG Mob. :- 9473942636

कार्यालय अधिशासी अभियन्ता,
खण्ड कार्यालय,
उ०प्र० जल निगम(ग्रामीण),सुहाग नगर, फिरोजाबाद।

पत्रांक:-
सेवा में,

1561 /

5/08/2025 / 33

दिनांक 14-8-2025

ई-मेल

विधालय प्रबन्धक,
वि०आर० पब्लिक स्कूल,
सराय हैबतपुर, विकास खण्ड- अरांव,
जिला- फिरोजाबाद।

विषय:- वाटर टेस्टिंग की जांच के सम्बन्ध में।

महोदय

उपरोक्त विषयक आपके पत्रांक शून्य दिनांक 05.08.2025 द्वारा उपलब्ध कराये गये
01 नग जल नमूने की जांच कर वाटर टेस्टिंग रिपोर्ट इस खण्ड द्वारा प्रेषित की जा रही है।

संलग्नक- उपरोक्तानुसार।

भवदीय

अधिशासी अभियन्ता



**District Level Water Analysis Laboratories of Uttar Pradesh
Jal Nigam (Rural) Firozabad
Lab Add- Civil line Dabarai Firozabad**

Test Report Water

Water Analysis Report					
Report no.	UPJN/R/FZD/0070/25	Issue Date	11/08/2025	Page no.	01
Customer Details					
Office Name & Address	Divisional Office, Executive Engineer, UP Jal Nigam (Rural), Firozabad				
Ref. Letter No. & Date	--				
Basic Details of Sample					
District	Firozabad	Block	Araon		
Gram panchayat	Habaitpur	Villago	Habaitpur		
Habitation	Habaitpur	Location	V R Public School Habaitpur Road, Sirsaganj Firozabad		
Water Source	Samar	Sample ID	FZD/0070/25		
Quantity of Sample	01 L	Date of S.C	05/08/2025		
Receiving Date	07/08/2025	S .Collector	Punam Singh		
Sample Depositor	Punam Singh	Analysis Completion Date	11/08/2025		
Analysis Start Date	8/08/2025				
Environmental Condition					
Temperature	25±3°C	Relative Humidity	60±15%		
Technical Data of Analysis					
S .No.	Analyzed Parameters	Observed Value	Specified Values as per BIS 10500 :2012		Ref .Method of Analysis
			Acceptable Limit	Permissible	
1.	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part 08):2017
2.	Turbidity(NTU)	1.980	1	5	IS 3025 (Part-10):2017
2	PH	8.240	6.5	8.5	IS 3025 (Part-11):2017
3	TDS(mg/L)	295.7	500	2000	IS 3025 (Part-16):2017
4	Alkalinity(mg/L)	200	200	600	IS 3025 (Part-23): 2019
5	Total Hardness (mg/L)	165	200	600	IS 3025 (Part-21):2019
6	Sulphate (mg/L)	16.57	200	400	APHA Method 23 rd Edition -4500-SO4 Method E (Turbidimetric Method):2017
7	Nitrate (mg/L)	43.05	45	No Relaxation	APHA Method 23 rd Edition -4500-NO3 Method B (UV Screening Method) 2017
9	Iron (mg /L)	0.05	1.0	No Relaxation	APHA Method 23 rd Edition-3500-Fe Method B (Phenanthroline Method) 2017
10	Chloride (mg/L)	35	250	1000	IS 3025(Part-32) :2019
11	Calcium (mg/L)	21	75	200	IS 3025 (Part-40): 2019
12	Magnesium (mg/L)	39	30	100	IS 3025 (Part-46): 2019
#BDL - Below Decection Limit, NA- Not Analyzed					
... Parameters(s) above permissible limit are in bold digits.					
Note 1-This Certificate refers only to the particular sample(s) submitted for testing.					
2-This Certificate shall not produced ,except in full, unless written permission for the publication no an approved abstract has been obtained from Head of Laboratory					
3-The test result reported in this certificate are valid at the time of and under the stated conditions of measurements.					
4-Sample will be stored up to 7days (incaseofnonp erishable Items only) from the date of issue of test report					
5-Parameters above permissible limit are written in Bold.					
Prepared by Chemist		Reviewed by			

END OF TEST REPORT



Annexure C

PERFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

DATED :-/...../.....

It is certified that an inspection team headed by ANADHESH KUMAR (chemist)
(Name of Officers with designation) from DISTRICT LAB. U.P.I.N. FIROZABAD PHED
inspected the V.R. PUBLIC SCHOOL HAIYATPUR ROAD SIRSAGANT FIROZABAD
(Name & Address of the school) on 08/08/2025 (date of inspection) and on the basis of
Water Test Report (Attached) bearing no. U.P.I.N./R/EZD/007025 dated 08/08/2025
of District LAB. U.P.I.N. FIROZABAD (PHED Lab) certified that
The V.R. PUBLIC SCHOOL (Name of school) has safe drinking water facilities
for the students and members of staff of the institution. School is also maintains the hygienic
sanitation condition in the school building & the campus as per norms prescribed by the Central
/state/U.T, Govt.

This certificate is valid till ONE YEAR

Signature with Seal: SR

Name: SHIVAM RAJPUT
ASSISTANT ENGINEER

Designation: DIVISION OFFICE
U.P. JAL NIGAM (R)
FIROZABAD

Name & Address of the Office / Department:

To

V.R. PUBLIC SCHOOL HAIYATPUR
ROAD SIRSAGANT FIROZABAD

(Name & Address of the Institution)

Note: The certificate is to be Issued by authorized officer / PHED Lab / local bodies